

San Francisco Fire Department Bureau of Fire Prevention Airport

Requirements for Temporary Certificate of Occupancy (TCO)

REQUIREMENTS:

1. Fire protection systems: fire sprinklers and fire suppression operational.
2. Fire alarm and smoke detection systems operational.
3. Exit paths/exit signage must be complete and in working condition.
4. Standby power and emergency lighting operational.
5. Required elevators operational/including recall and fire department mode.
6. Fire separations: including doors, fire dampers, enclosures and seals installed and in working condition.

These are the minimum requirements for the SFFD when considering the granting of a TCO